

2024 Annual Drinking Water Quality Report (Testing Performed January through December 2023)

WATER WORKS OF THE TOWN OF SWEETWATER

PWSID AL0000918

P.O. Box 33

Sweetwater, AL 36782

Phone 334-994-4120

www.townofsweetwater.com

We are pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources.

Water Source	One (1) groundwater well producing from the Nanafalia aquifer	
Other Connections	Myrtlewood Water System as back up source	
Water Treatment	Chlorination	
Storage Capacity	One tank with a total capacity of 100,000 gallons	
Number of Customers	Approximately 155	
City Council		
	Chad Broussard, Mayor	Miranda Blakeney, Council
	Jimmy Davis, Mayor pro tem	Ken McClantoc, Council
	Sandra Etheridge, Council	Patrick Robison, Council

Source Water Assessment

In compliance with the Alabama Department of Environmental Management (ADEM), Water Works of the Town of Sweetwater has developed a Source Water Assessment plan that will assist in protecting our water sources. This plan provides additional information such as potential sources of contamination. It includes a susceptibility analysis, which classifies potential contaminants as high, moderate, or non-susceptible to contaminating the water source. The assessment has been performed, public notification was completed on July 8, 2002, and the plan has been approved by ADEM. A copy of the report is available in our office for review during regular business hours, or you may purchase a copy upon request for a nominal reproduction fee. Please help us make this effort worthwhile by protecting our source water. Carefully follow instructions on pesticides and herbicides you use for your lawn and garden, and properly dispose of household chemicals, paints and waste oil.

General Information

All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. MCL's, defined in a List of Definitions in this report, are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and it can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, storm water run-off, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water.

Some people may be more vulnerable to contaminants in drinking water than the general population. People who are immunocompromised such as cancer patients undergoing chemotherapy, organ transplant recipients, HIV/AIDS positive or other immune system disorders, some elderly, and infants can be particularly at risk from infections. People at risk should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Based on a study conducted by ADEM with the approval of the EPA a statewide waiver for the monitoring of asbestos and dioxin was issued. Thus, monitoring for these contaminants was not required.

Information about Lead

Lead in drinking water is rarely found in source water but is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Use *only* water from the cold-water tap for drinking, cooking, and *especially for making baby formula*. Hot water is more likely to cause leaching of lead from plumbing materials. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. These recommended actions are very important to the health of your family. Lead levels in your drinking water are likely to be higher if:

- Your home or water system has lead pipes, or
- Your home has faucets or fittings made of brass which contains some lead, or
- Your home has copper pipes with lead solder and you have naturally soft water, and
- Water often sits in the pipes for several hours.

If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water hotline or at www.epa.gov/safewater/lead.

Questions?

We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the fourth Monday of the following months, January, April, July, and October, at 5:30 P.M. at Town Hall, 31380 AL Hwy 10.. If you have any questions about this report or concerning your water utility, please contact Terry Tyson at 334-422-1408 or Corey Martin at 334-413-0983. More information about contaminants to drinking water and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (1-800-426-4791).

Monitoring Schedule and Results

Your water sources are routinely monitored for constituents in your drinking water according to Federal and State laws. ADEM allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. This report contains results from the most recent monitoring which was performed in accordance with the regulatory schedule.

Constituents Monitored	Sweetwater	Myrtlewood
Inorganic Contaminants	2022	2022
Lead/Copper	2023	2023
Microbiological Contaminants	current	current
Nitrates	2023	2023
Radioactive Contaminants	2019	2019
Synthetic Organic Contaminants (including herbicides and pesticides)	2023	2023
Volatile Organic Contaminants	2023	2023
Disinfection By-products	2023	2023
PFAS Contaminants	2020	2020

The table below shows only those contaminants that had some level of detection. We are pleased to report that our drinking water meets federal and state requirements. This report shows our water quality and what it means.

Sweetwater Water Works DETECTED DRINKING WATER CONTAMINANTS						
Contaminants	Violation Y/N	Level Detected	Unit Msmt	MCLG	MCL	Likely Source of Contamination
Barium	NO	0.03	ppm	2	2	Drilling & refinery discharge; erosion
Copper	NO	0.210 *	ppm	1.3	AL=1.3	Household plumbing corrosion; erosion; preservative leaching
Lead	NO	0.0010 *	ppm	0	AL=0.015	Household plumbing corrosion, erosion
TTHM [Total trihalomethanes]	YES	Maxx LRAA 93.5 (42.0-140)	ppb	0	80	By-product of drinking water chlorination.
HAA5 [Total haloacetic acids]	NO	Maxx LRAA 17.4 (7.60-23.0)	ppb	0	60	By-product of drinking water chlorination
Unregulated Contaminants						
Chloroform	NO	3.90	ppb	70	n/a	Naturally occurring; industrial discharge or agricultural runoff
Bromodichloromethane	NO	7.40	ppb	0	n/a	Naturally occurring; industrial discharge or agricultural runoff
Chlorodibromomethane	NO	12.0	ppb	60	n/a	Naturally occurring; industrial discharge or agricultural runoff
Bromoform	NO	5.10	ppb	0	n/a	Naturally occurring; industrial discharge or agricultural runoff
Secondary Contaminants						
Chloride	NO	56.9	ppm	none	250	Naturally occurring in the environment or from runoff
Hardness	NO	88.5	ppm	none	none	Naturally occurring or from water additives
Iron	NO	0.04	ppm	none	0.30	Naturally occurring; erosion; leaching from pipes
pH	NO	7.4	S.U.	none	none	Naturally occurring or from water additives
Sodium	NO	126	ppm	none	none	Naturally occurring in the environment
Sulfate	NO	14.7	ppm	none	250	Naturally occurring in the environment; erosion
Total Dissolved Solids	NO	429	ppm	none	500	Naturally occurring in the environment or from runoff

* Figure shown is 90th percentile and number of sites above the Action Level (AL) = 0

Below is a list of PFAS contaminants for which our source was monitored in 2020 as required and the results of that monitoring. For more information on PFAS contaminants, please refer to www.epa.gov/pfas. PFAS was not detected in our drinking water.

Sweetwater Water Works - PFAS					
Contaminant	Unit	Detected	Contaminant	Unit	Detected
11CI-PF3OUdS (11-chloroicosafuoro-3-oxaundecane-1-sulfonic acid)	ppb	ND	Perfluoroheptanoic acid	ppb	ND
9CI-PF3ONS (9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid)	ppb	ND	Perfluorohexanesulfonic acid	ppb	ND
ADONA (4,8-dioxa-3H-perfluorononanoic acid)	ppb	ND	Perfluorononanoic acid	ppb	ND
HFPO-DA (Hexafluoropropylene oxide dimer acidA)	ppb	ND	Perfluorooctanesulfonic acid	ppb	ND
NEtFOSAA (N-ethylperfluorooctanesulfonamidoacetic acid)	ppb	ND	Perfluorooctanoic acid	ppb	ND
NMeFOSAA (N-methylperfluorooctanesulfonamidoacetic acid)	ppb	ND	Perfluorotetradecanoic acid	ppb	ND
Perfluorobutanesulfonic acid	ppb	ND	Perfluorotridecanoic acid	ppb	ND
Perfluorodecanoic acid	ppb	ND	Perfluoroundecanoic acid	ppb	ND
Perfluorohexanoic acid	ppb	ND	Total PFAS	ppb	ND
Perfluorododecanoic acid	ppb	ND			

Sweetwater 2023 Public Notice Violation: Sweetwater Water and Sewer Board incurred a public notice violation for failing to submit a Proof of Notification to ADEM by January 15, 2024. We were required to perform public notice for the TTHM MCL violation detailed in the next paragraph and to submit Proof of Notification to ADEM by January 15, 2024. We failed to submit it on time. We have since performed public notice and submitted the Proof of Notification to ADEM.

Sweetwater 2023 TTHM MCL Violation: Sweetwater Water and Sewer Board recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation. We routinely monitor for the presence of drinking water contaminants. Testing results we received in November of 2023 show that our system exceeds the standard or maximum contaminant level (MCL) for Total Trihalomethanes (TTHM). The standard for Total Trihalomethanes is 0.080 mg/L. The chart below lists the locations, disinfectant byproduct and levels that exceeded the maximum contaminant level.

Location	Contaminant	Quarter	Level ug/L
2454 Beaver Creek Road	TTHM	Oct - Dec 2023	86.0

This is not an immediate risk. If it had been, you would have been notified immediately. However, some people who drink water containing total trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer. However, if you have specific health concerns, consult your doctor. Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, etc.) You can do this by posting this notice in a public place or distributing copies by hand or mail to your community. The presence of TTHM, is a disinfection byproduct and is a result of the interaction of the organic compounds in the source water and required chlorine disinfection. Currently, there is not any available

method of controlling the presence of TTHM or other disinfection byproducts in place. If necessary, we will evaluate engineering controls to limit the occurrence in the future. Should you have any questions concerning this violation or monitoring requirements, please contact the water treatment operators, Terry Tyson at 334-422-1408 or Corey Martin, 334-413-0983 or by mail at 31380 AL HWY 10, Sweet Water, AL 36782.

Sweetwater 2023 MORs Reporting Non-compliance: Sweetwater Water and Sewer Board has incurred a reporting violation by failing to submit the September 2023 MOR to the Department in a timely manner. ADEM Admin. Coder. 335-7-4-.1 I(f) requires that a copy of the Monthly Operation Data Report be provided to ADEM within 10 days after the end of each report period. We have since submitted the MOR specified and have taken steps to ensure that the correct preparation and submittal of these monthly reports has become part of our standard monthly procedures. Your drinking water was monitored as required during the time of the late reports, and the results showed that the water quality was not adversely affected. If it had been, we would have notified you immediately. Should you have any questions concerning this violation or our monitoring requirements, please contact please contact Terry Tyson at 334-422-1408 or Corey Martin at 334-413-0983.

Myrtlewood Water System DETECTED DRINKING WATER CONTAMINANTS						
Contaminants	Violation Y/N	Level Detected	Unit Msmt	MCLG	MCL	Likely Source of Contamination
Total coliform bacteria	NO	1 positive*	Present or Absent	0	presence in 5% of samples	Naturally present in the environment
Barium	NO	ND-0.03	ppm	2	2	Discharge from drilling & metal refineries; erosion
Copper	NO	0.820 ** 1 > AL	ppm	1.3	AL=1.3	Household plumbing corrosion; erosion; wood preservative leaching
Fluoride	NO	0.34-0.49	ppm	4	4	Erosion; water additive for teeth; fertilizer & aluminum factory discharge
Lead	NO	0.001 ** 0 > AL	ppm	0	AL=0.015	Corrosion of household plumbing systems, erosion
TTHM [Total trihalomethanes]	NO	LRAA 6.20-55.3	ppb	0	80	By-product of drinking water chlorination
HAA5 [Total haloacetic acids]	NO	LRAA 1.38-10.5	ppb	0	60	By-product of drinking water chlorination
Unregulated Contaminants						
Chloroform	NO	3.10	ppb	n/a	n/a	Naturally occurring in the environment or from runoff
Bromodichloromethane	NO	8.20	ppb	n/a	n/a	Naturally occurring in the environment or from runoff
Chlorodibromomethane	NO	17.0	ppb	n/a	n/a	Naturally occurring in the environment or from runoff
Bromoform	NO	9.00	ppb	n/a	n/a	Naturally occurring in the environment or from runoff
Secondary Contaminants						
Chloride	NO	ND-59.8	ppm	n/a	250	Naturally occurring or from discharge or runoff
Hardness	NO	7.3-101	ppm	n/a	n/a	Naturally occurring or from water treatment
Iron	NO	0.08-0.10	ppm	n/a	0.30	Naturally occurring; erosion; leaching from pipes
pH	NO	7.4-8.4	S.U.	n/a	n/a	Naturally occurring or from water treatment
Sodium	NO	124-186	ppm	n/a	n/a	Naturally occurring in the environment
Sulfate	NO	6.3-13.1	ppm	n/a	250	Naturally occurring or from discharge or runoff
Total Dissolved Solids	NO	386-426	ppm	n/a	500	Naturally occurring or from discharge or runoff

* One (1) positive sample occurred in May 2023. All follow up samples were negative for coliform bacteria. This was not a MCL violation.

** Figure shown is 90th percentile of distribution sites sampled. For copper: number of sites above the Action Level (AL) = 1. For lead: number of sites above the AL = 0.

Below is a list of PFAS contaminants for which our source was monitored in 2020 as required and the results of that monitoring. For more information on PFAS contaminants, please refer to www.epa.gov/pfas. PFAS was not detected in our drinking water.

Myrtlewood Water System PFAS CONTAMINANTS					
Contaminant	Unit Msmt	Level Detected	Contaminant	Unit Msmt	Level Detected
11Cl-PF3OUdS (11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid)	ppb	ND	Perfluoroheptanoic acid	ppb	ND
9Cl-PF3ONS (9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid)	ppb	ND	Perfluorohexanesulfonic acid	ppb	ND
ADONA (4,8-dioxa-3H-perfluorononanoic acid)	ppb	ND	Perfluorononanoic acid	ppb	ND
HFPO-DA (Hexafluoropropylene oxide dimer acidA)	ppb	ND	Perfluorooctanesulfonic acid	ppb	ND
NEtFOSAA (N-ethylperfluorooctanesulfonamidoacetic acid)	ppb	ND	Perfluorooctanoic acid	ppb	ND
NMeFOSAA (N-methylperfluorooctanesulfonamidoacetic acid)	ppb	ND	Perfluorotetradecanoic acid	ppb	ND
Perfluorobutanesulfonic acid	ppb	ND	Perfluorotridecanoic acid	ppb	ND
Perfluorodecanoic acid	ppb	ND	Perfluoroundecanoic acid	ppb	ND
Perfluorohexanoic acid	ppb	ND	Total PFAS	ppb	ND
Perfluorododecanoic acid	ppb	ND			

Definitions

Action Level- the concentration of a contaminant that, if exceeded, triggers treatment or other requirements which a water system must follow.

Coliform Absent (ca)- Laboratory analysis indicates that the contaminant is not present.

Cryptosporidium- a microscopic parasite that can cause disease, mainly diarrhea, if swallowed.

Disinfection byproducts (DBPs)- are formed when disinfectants used in water treatment plants react with bromide and/or natural organic matter (i.e., decaying vegetation) present in the source water.

Distribution System Evaluation (DSE)-a 4-quarter study to identify distribution system locations with high concentrations of DBPs.

Maximum Contaminant Level (MCL) is the highest level of a contaminant that is allowed in drinking water.

Maximum Contaminant Level Goal (MCLG)- the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL)- the highest level of a disinfectant allowed in drinking water

Maximum Residual Disinfectant Level Goal (MRDLG) the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Millirems per year (mrem/yr)-measure of radiation absorbed by the body.

Nephelometric Turbidity Unit (NTU)-a measure of the clarity of water.

Non-Detect (ND)- laboratory analysis indicates that the constituent is not present above detection limits of lab equipment.

Parts per billion (ppb) or Micrograms per liter (µg/l)-one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per million (ppm) or Milligrams per liter (mg/l)-one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per quadrillion (ppq) or Picograms per liter (picograms/l)-one part per quadrillion corresponds to one minute in 2,000,000,000 years, or a single penny in \$10,000,000,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l)-one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Picocuries per liter (pCi/L)-picocuries per liter is a measure of the radioactivity in water.

Running Annual Average (LRAA)-yearly average of all the DPB results at each specific sampling site in the distribution system.

Standard Units (S.U.)-pH of water measures the water's balances of acids and bases and is affected by temperature and carbon dioxide gas.

Treatment Technique (TT)- a required process intended to reduce the level of a contaminant in drinking water.

Variances & Exemptions (V&E)-State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Below is a table of contaminants for which the Environmental Protection Agency and the Alabama Department of Environmental Management require testing where applicable. These contaminants were not detected in your drinking water unless they are also listed in the Detected Drinking Water Contaminants table elsewhere in this report.

STANDARD LIST OF PRIMARY DRINKING WATER CONTAMINANTS					
Contaminant	MCL	Unit of Msmt	Contaminant	MCL	Unit of Msmt
Bacteriological Contaminants			cis-1,2-Dichloroethylene	70	ppb
Total Coliform Bacteria	<5%	present/absent	trans-1,2-Dichloroethylene	100	ppb
Fecal Coliform and E. coli	0	present/absent	Dichloromethane	5	ppb
Turbidity	TT	NTU	1,2-Dichloropropane	5	ppb
Cryptosporidium	TT	Calc.organisms/l	Di (2-ethylhexyl)adipate	400	ppb
Radiological Contaminants			Di (2-ethylhexyl)phthalate	6	ppb
Beta/photon emitters	4	mrem/yr	Dinoseb	7	ppb
Alpha emitters	15	pCi/l	Dioxin [2,3,7,8-TCDD]	30	ppq
Combined radium	5	pCi/l	Diquat	20	ppb
Uranium	30	pCi/l	Endothal	100	ppb
Inorganic Chemicals			Endrin	2	ppb
Antimony	6	ppb	Epichlorohydrin	TT	TT
Arsenic	10	ppb	Ethylbenzene	700	ppb
Asbestos	7	MFL	Ethylene dibromide	50	ppt
Barium	2	ppm	Glyphosate	700	ppb
Beryllium	4	ppb	Heptachlor	400	ppt
Cadmium	5	ppb	Heptachlor epoxide	200	ppt
Chromium	100	ppb	Hexachlorobenzene	1	ppb
Copper	AL=1.3	ppm	Hexachlorocyclopentadiene	50	ppb
Cyanide	200	ppb	Lindane	200	ppt
Fluoride	4	ppm	Methoxychlor	40	ppb
Lead	AL=15	ppb	Oxamyl [Vydate]	200	ppb
Mercury	2	ppb	Polychlorinated biphenyls	0.5	ppb
Nitrate	10	ppm	Pentachlorophenol	1	ppb
Nitrite	1	ppm	Picloram	500	ppb
Selenium	.05	ppm	Simazine	4	ppb
Thallium	.002	ppm	Styrene	100	ppb
Organic Contaminants			Tetrachloroethylene	5	ppb
2,4-D	70	ppb	Toluene	1	ppm
Acrylamide	TT	TT	Toxaphene	3	ppb
Alachlor	2	ppb	2,4,5-TP(Silvex)	50	ppb
Atrazine	3	ppb	1,2,4-Trichlorobenzene	.07	ppm
Benzene	5	ppb	1,1,1-Trichloroethane	200	ppb
Benzo(a)pyrene [PAHs]	200	ppt	1,1,2-Trichloroethane	5	ppb
Carbofuran	40	ppb	Trichloroethylene	5	ppb
Carbon tetrachloride	5	ppb	Vinyl Chloride	2	ppb
Chlordane	2	ppb	Xylenes	10	ppm
Chlorobenzene	100	ppb	Disinfectants & Disinfection Byproducts		
Dalapon	200	ppb	Chlorine	4	ppm
Dibromochloropropane	200	ppt	Chlorine Dioxide	800	ppb
1,2-Dichlorobenzene	1000	ppb	Chloramines	4	ppm
1,4-Dichlorobenzene (para)	75	ppb	Bromate	10	ppb
o-Dichlorobenzene	600	ppb	Chlorite	1	ppm
1,2-Dichloroethane	5	ppb	HAA5 [Total haloacetic acids]	60	ppb
1,1-Dichloroethylene	7	ppb	TTHM [Total trihalomethanes]	80	ppb
LIST OF SECONDARY CONTAMINANTS					
Alkalinity, Total (as CA, Co ₃)	Copper	Manganese	Specific Conductance		
Aluminum	Corrosivity	Odor	Sulfate		
Calcium, as Ca	Foaming agents (MBAS)	Nickel	Total Dissolved Solids		
Carbon Dioxide	Hardness	pH	Zinc		
Chloride	Iron	Silver			
Color	Magnesium	Sodium			
LIST OF UNREGULATED CONTAMINANTS					
Aldicarb	Chloroethane	Dieldrin	Propachlor		
Aldicarb Sulfone	Chloroform	Hexachlorobutadiene	N-Propylbenzene		
Aldicarb Sulfoxide	Chloromethane	3-Hydroxycarbofuran	Propachlor		
Aldrin	O-Chlorotoluene	Isopropylbenzene	1,1,1,2-Tetrachloroethane		
Bromoacetic Acid	P-Chlorotoluene	p-Isopropyltoluene	1,1,2,2-Tetrachloroethane		
Bromobenzene	Dibromochloromethane	M-Dichlorobenzene	Tetrachloroethene		
Bromochloromethane	1,2-Dibromoethane	Methomyl	Trichloroacetic Acid		
Bromodichloromethane	Dibromomethane	Methylene chloride	1,2,3-Trichlorobenzene		
Bromoform	1,1-Dichloroethane	Methyl tert-butyl ether	Trichloroethene		
Bromomethane	1,3-Dichloropropane	Metolachlor	Trichlorofluoromethane		
Butachlor	2,2-Dichloropropane	Metribuzin	1,2,3-Trichloropropane		
N-Butylbenzene	1,1-Dichloropropene	MTBE	1,2,4-Trimethylbenzene		
Sec-Butylbenzene	1,3-Dichloropropene	Naphthalene	1,3,5-Trimethylbenzene		
Tert - Butylbenzene	Dicamba	1-Naphthol			
Carbaryl	Dichlorodifluoromethane	Paraquat			